

NO.WRD/WDXI/SDIII/TECH/W.F.149/2021/2022-23/ 26. Dated:- 03-11-2022

GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Flood mitigation measures to the banks of nallah at Deulmol- Shirvoi, Quepem in ward No.4 of Quepem Muncipal Council in Quepem Taluka.

SAMPLE SENT BY: AE, SD V, WD XII, WRD, Quepem- Goa.

NAME OF THE AGENCY					TESTING PERIOD		28 days.		
REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
1.1	F.149/15/2021						235.56		No. WRD/WD XII/SD V/
	F.149/16/2021	26-09-2022	25-10-2022	Foundation	1.2.4	210 kg/cm2	231.11	234.08	F.15/145/2022-23.
	F.149/17/2021						235.56		DATED: 04-10-2022.
1.2	F.149/18/2021						240.00		
	F.149/19/2021	26-09-2022	25-10-2022	Foundation	1.2.4	210 kg/cm2	235.56	237.04	do
	F.149/20/2021						235.56		
1.3	F.149/21/2021						240.00		
	F.149/22/2021	26-09-2022	25-10-2022	Foundation	1.2.4	210 kg/cm2	240.00	238.52	do
	F.149/23/2021						235.56		
1.4	F.149/24/2021						235.56		
	F.149/25/2021	26-09-2022	25-10-2022	Foundation	1.2.4	210 kg/cm2	235.56	235.56	do
	F.149/26/2021						235.56		
2.1	F.149/27/2021						226.67		
	F.149/28/2021	27-09-2022	25-10-2022	Superstructure	1.2.4	210 kg/cm2	231.11	229.63	do
	F.149/29/2021						231.11		
2.2	F.149/30/2021						231.11		
	F.149/31/2021	27-09-2022	25-10-2022	Superstructure	1.2.4	210 kg/cm2	231.11	231.11	do
	F.149/32/2021						231.11		
3	F.149/33/2021						235.56		
	F.149/34/2021	28-09-2022	26-10-2022	Superstructure	1.2.4	210 kg/cm2	231.11	232.59	do
	F.149/35/2021						231.11		

JUNIOR ENGINEER.

ASSISTANT ENGINEER