

NO.WRD/WDXI/SDIII/TECH/W.F.150/2021/2022-23/ 27.

Dated:- 03-11-2022.

GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Providing urgent protective measures to the collapsed portion near the bandhara piers of Sarzora tank at Sarzora in Salcete Taluka.

SAMPLE SENT BY: AE, SD V, WD XII, WRD, Quepem- Goa.

NAME OF THE AGENCY

TESTING PERIOD

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
1.1	F.150/15/2021						240.00		No. WRD/WD XII/SD V/
	F.150/16/2021	26-09-2022	25-10-2022	Foundation	1.2.4	210 kg/cm2	240.00	240.00	F.15/144/2022-23.
	F.150/17/2021						240.00		DATED: 04-10-2022.
1.2	F.150/18/2021						235.56		
	F.150/19/2021	26-09-2022	25-10-2022	Foundation	1.2.4	210 kg/cm2	240.00	237.04	do
	F.150/20/2021						235.56		
1.3	F.150/21/2021						231.11		
	F.150/22/2021	26-09-2022	25-10-2022	Foundation	1.2.4	210 kg/cm2	240.00	237.04	do
	F.150/23/2021						240.00		
1.4	F.150/24/2021						235.56		
	F.150/25/2021	26-09-2022	25-10-2022	Foundation	1.2.4	210 kg/cm2	240.00	238.52	do
	F.150/26/2021						240.00		
2	F.150/27/2021						244.44		
	F.150/28/2021	27-09-2022	25-10-2022	1st Lift	1.2.4	210 kg/cm2	240.00	240.00	do
	F.150/29/2021						235.56		
3	F.150/30/2021						235.56		
	F.150/31/2021	28-09-2022	26-10-2022	2nd Lift	1.2.4	210 kg/cm2	240.00	237.04	do
	F.150/32/2021						235.56		
4	F.150/33/2021						226.67		
	F.150/34/2021	29-09-2022	27-10-2022	3rd Lift	1.2.4	210 kg/cm2	235.56	232.60	do
	F.150/35/2021						235.56		

JUNIOR ENGINEER.

ASSISTANT ENGINEER