

**GOVERNMENT OF GOA**  
**SD III (QC) , WRD, GOGAL, MARGAO- GOA.**

**NAME OF THE WORK:** Construation of Retaining wall for water tank in Sy.No. 42/1 in V.P. Davorlim in Navelim Constituency.

**SAMPLE SENT BY:** AE, SD I, WD II, WRD, Rawanfond- Goa.

NAME OF THE AGENCY				TESTING PERIOD		28 days.			
REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
1.1	F.02/05/2021						164.44		No. WRD/SD I/WD II/ F.Estt/716/2021-22 <b>DATED:- 28-01-2022</b>
	F.02/06/2021	10/1/2022	7/2/2022	Foundation	1.2.4	150 kg/cm2	160.00	162.96	
	F.02/07/2021						164.44		
1.2	F.02/08/2021						164.44		do
	F.02/09/2021	10/1/2022	7/2/2022	Foundation	1.2.4	150 kg/cm2	164.44	165.92	
	F.02/10/2021						168.89		
2.1	F.02/11/2021						164.44		do
	F.02/12/2021	11/1/2022	8/2/2022	Foundation	1.2.4	150 kg/cm2	164.44	165.92	
	F.02/13/2021						168.89		
2.2	F.02/14/2021						168.89		do
	F.02/15/2021	11/1/2022	8/2/2022	Foundation	1.2.4	150 kg/cm2	168.89	167.41	
	F.02/16/2021						164.44		
3.1	F.02/17/2021						164.44		do
	F.02/18/2021	12/1/2022	9/2/2022	Foundation	1.2.4	150 kg/cm2	164.44	165.92	
	F.02/19/2021						168.89		
3.2	F.02/20/2021						168.89		do
	F.02/21/2021	12/1/2022	9/2/2022	Foundation	1.2.4	150 kg/cm2	168.89	167.41	
	F.02/22/2021						164.44		
4.1	F.02/23/2021						168.89		do
	F.02/24/2021	13-01-2022	10/2/2022	Foundation	1.2.4	150 kg/cm2	168.89	167.41	
	F.02/25/2021						164.44		
4.2	F.02/26/2021						168.89		do
	F.02/27/2021	13-01-2022	10/2/2022	Foundation	1.2.4	150 kg/cm2	164.44	165.92	
	F.02/28/2021						164.44		

**JUNIOR ENGINEER.**

**ASSISTANT ENGINEER**

**GOVERNMENT OF GOA**

## SD III (QC) , WRD, GOGAL, MARGAO- GOA.

**NAME OF THE WORK:** Construction of Retaining wall for water tank in Sy.No. 42/1 in V.P. Davorlim in Navelim Constituency.

**SAMPLE SENT BY:** AE, SD I, WD II, WRD, Rawanfond- Goa.

**NAME OF THE AGENCY**

**TESTING PERIOD**

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPORTION	REQUIRED STRENGTH	Comp sth in Kg/cm <sup>2</sup>	Avg. Comp Kg/cm <sup>2</sup>	LETTER No / DATED
5.1	F.02/29/2021						164.44		No. WRD/SD I/WD II/ F.Estt/716/2021-22 <b>DATED:- 28-01-2022</b>
	F.02/30/2021	14-01-2022	11/2/2022	Wall	1.2.4	150 kg/cm <sup>2</sup>	160.00	162.96	
	F.02/31/2021						164.44		
5.2	F.02/32/2021						164.44		do
	F.02/33/2021	14-01-2022	11/2/2022	Wall	1.2.4	150 kg/cm <sup>2</sup>	164.44	165.92	
	F.02/34/2021						168.89		
6.1	F.02/35/2021						168.89		do
	F.02/36/2021	15-01-2022	12/2/2022	Wall	1.2.4	150 kg/cm <sup>2</sup>	164.44	165.92	
	F.02/37/2021						164.44		
6.2	F.02/38/2021						168.89		do
	F.02/39/2021	15-01-2022	12/2/2022	Wall	1.2.4	150 kg/cm <sup>2</sup>	168.89	167.41	
	F.02/40/2021						164.44		
7.1	F.02/41/2021						164.44		do
	F.02/42/2021	17-01-2022	14-02-2022	Wall	1.2.4	150 kg/cm <sup>2</sup>	164.44	165.92	
	F.02/43/2021						168.89		
7.2	F.02/44/2021						168.89		do
	F.02/45/2021	17-01-2022	14-02-2022	Wall	1.2.4	150 kg/cm <sup>2</sup>	168.89	167.41	
	F.02/46/2021						164.44		
8.1	F.02/47/2021						164.44		do
	F.02/48/2021	18-01-2022	15-02-2022	Wall	1.2.4	150 kg/cm <sup>2</sup>	164.44	165.92	
	F.02/49/2021						168.89		
8.2	F.02/50/2021						164.44		do
	F.02/51/2021	18-01-2022	15-02-2022	Wall	1.2.4	150 kg/cm <sup>2</sup>	164.44	165.92	
	F.02/52/2021						168.89		

JUNIOR ENGINEER.

ASSISTANT ENGINEER

GOVERNMENT OF GOA

## SD III (QC) , WRD, GOGAL, MARGAO- GOA.

**NAME OF THE WORK:** Construction of Retaining wall for water tank in Sy.No. 42/1 in V.P. Davorlim in Navelim Constituency.

**SAMPLE SENT BY:** AE, SD I, WD II, WRD, Rawanfond- Goa.

**NAME OF THE AGENCY**

**TESTING PERIOD**

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
9.1	F.02/53/2021						164.44		No. WRD/SD I/WD II/ F.Estt/716/2021-22 <b>DATED:- 28-01-2022</b>
	F.02/54/2021	19-01-2022	16-02-2022	Wall	1.2.4	150 kg/cm2	164.44	165.92	
	F.02/55/2021						168.89		
9.2	F.02/56/2021						164.44		do
	F.02/57/2021	19-01-2022	16-02-2022	Wall	1.2.4	150 kg/cm2	164.44	165.92	
	F.02/58/2021						168.89		
10.1	F.02/59/2021						168.89		do
	F.02/60/2021	20-01-2022	17-02-2022	Wall	1.2.4	150 kg/cm2	168.89	167.41	
	F.02/61/2021						164.44		
10.2	F.02/62/2021						164.44		do
	F.02/63/2021	20-01-2022	17-02-2022	Wall	1.2.4	150 kg/cm2	164.44	165.92	
	F.02/64/2021						168.89		
11.1	F.02/65/2021						168.89		do
	F.02/66/2021	21-01-2022	18-02-2022	Wall	1.2.4	150 kg/cm2	168.89	167.41	
	F.02/67/2021						164.44		
11.2	F.02/68/2021						168.89		do
	F.02/69/2021	21-01-2022	18-02-2022	Wall	1.2.4	150 kg/cm2	168.89	167.41	
	F.02/70/2021						164.44		
12.1	F.02/71/2021						164.44		do
	F.02/72/2021	22-01-2022	19-02-2022	Wall	1.2.4	150 kg/cm2	164.44	165.92	
	F.02/73/2021						168.89		
12.2	F.02/74/2021						168.89		do
	F.02/75/2021	22-01-2022	19-02-2022	Wall	1.2.4	150 kg/cm2	168.89	167.41	
	F.02/76/2021						164.44		

**JUNIOR ENGINEER.**

**ASSISTANT ENGINEER**