

**GOVERNMENT OF GOA**  
**SD III (QC) , WRD, GOGAL, MARGAO- GOA.**

**NAME OF THE WORK:** Re- Construction of Pipe Culvert with RCC slab at Ghodegal, Ambaulim in cuncolim Constituency.

**SAMPLE SENT BY:** AE, SD III, WD XIV, WRD, Cuncolim- Goa.

**NAME OF THE AGENCY**

**TESTING PERIOD**

07 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
1.1	F.61/05/2021						115.56		No. WRD/SD III/WD XIV/ W.F.10/2021-22/209 <b>DATED:- 11-01-2022.</b>
	F.61/06/2021	7/1/2022	14-01-2022	RCC slab culvert abutment wall	1.2.4	100 kg/cm2	120.00	118.52	
	F.61/07/2021			foundation right side			120.00		
1.2	F.61/08/2021						115.56		do
	F.61/09/2021	7/1/2022	14-01-2022	RCC slab culvert abutment wall	1.2.4	100 kg/cm2	120.00	115.56	
	F.61/10/2021			foundation right side			111.11		
2.1	F.61/11/2021						115.56		do
	F.61/12/2021	7/1/2022	14-01-2022	RCC slab culvert abutment wall	1.2.4	100 kg/cm2	124.44	117.04	
	F.61/13/2021			foundation left side			111.11		
2.2	F.61/14/2021						120.00		do
	F.61/15/2021	7/1/2022	14-01-2022	RCC slab culvert abutment wall	1.2.4	100 kg/cm2	120.00	117.04	
	F.61/16/2021			foundation left side			111.11		
3.1	F.61/17/2021						115.56		do
	F.61/18/2021	8/1/2022	15-01-2022	RCC slab culvert abutment wall	1.2.4	100 kg/cm2	115.55	117.04	
	F.61/19/2021			foundation right side			120.00		
3.2	F.61/20/2021						115.56		do
	F.61/21/2021	8/1/2022	15-01-2022	RCC slab culvert abutment wall	1.2.4	100 kg/cm2	115.56	115.56	
	F.61/22/2021			foundation right side			115.56		
3.3	F.61/23/2021						111.11		do
	F.61/24/2021	8/1/2022	15-01-2022	RCC slab culvert abutment wall	1.2.4	100 kg/cm2	115.56	115.56	
	F.61/25/2021			foundation right side			120.00		
3.4	F.61/26/2021						115.56		do
	F.61/27/2021	8/1/2022	15-01-2022	RCC slab culvert abutment wall	1.2.4	100 kg/cm2	115.56	117.04	
	F.61/28/2021			foundation right side			120.00		

**JUNIOR ENGINEER.**

**ASSISTANT ENGINEER**

**GOVERNMENT OF GOA**  
**SD III (QC) , WRD, GOGAL, MARGAO- GOA.**

**NAME OF THE WORK:** Re- Construction of Pipe Culvert with RCC slab at Ghodegal, Ambaulim in cuncolim Constituency.

**SAMPLE SENT BY:** AE, SD III, WD XIV, WRD, Cuncolim- Goa.

**NAME OF THE AGENCY**

**TESTING PERIOD**

07 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
4.1	F.61/29/2021						115.56		No. WRD/SD III/WD XIV/ W.F.10/2021-22/209 <b>DATED:- 11-01-2022.</b>
	F.61/30/2021	8/1/2022	15-01-2022	RCC slab culvert abutment wall	1.2.4	100 kg/cm2	120.00	118.52	
	F.61/31/2021			foundation left side			120.00		
4.2	F.61/32/2021						115.56		do
	F.61/33/2021	8/1/2022	15-01-2022	RCC slab culvert abutment wall	1.2.4	100 kg/cm2	120.00	115.56	
	F.61/34/2021			foundation left side			111.11		
4.3	F.61/35/2021						115.56		do
	F.61/36/2021	8/1/2022	15-01-2022	RCC slab culvert abutment wall	1.2.4	100 kg/cm2	124.44	117.04	
	F.61/37/2021			foundation left side			111.11		
4.4	F.61/38/2021						120.00		do
	F.61/39/2021	8/1/2022	15-01-2022	RCC slab culvert abutment wall	1.2.4	100 kg/cm2	115.56	118.52	
	F.61/40/2021			foundation left side			120.00		
5.1	F.61/41/2021						120.00		No. WRD/SD III/WD XIV/ W.F.10/2021-22/212 <b>DATED:- 14-01-2022.</b>
	F.61/90/2021	10/1/2022	17-01-2022	Right side Abutment wall of slab culvert	1.2.4	100 kg/cm2	120.00	117.04	
	F.61/91/2021						111.11		
5.2	F.61/92/2021						115.56		do
	F.61/93/2021	10/1/2022	17-01-2022	Right side Abutment wall of slab culvert	1.2.4	100 kg/cm2	115.55	117.04	
	F.61/94/2021						120.00		
5.3	F.61/95/2021						115.56		do
	F.61/96/2021	10/1/2022	17-01-2022	Right side Abutment wall of slab culvert	1.2.4	100 kg/cm2	115.56	115.56	
	F.61/97/2021						115.56		
5.4	F.61/98/2021						111.11		do
	F.61/99/2021	10/1/2022	17-01-2022	Right side Abutment wall of slab culvert	1.2.4	100 kg/cm2	115.56	115.56	
	F.61/100/2021						120.00		

**JUNIOR ENGINEER.**

**ASSISTANT ENGINEER**

**GOVERNMENT OF GOA**  
**SD III (QC) , WRD, GOGAL, MARGAO- GOA.**

**NAME OF THE WORK:** Re- Construction of Pipe Culvert with RCC slab at Ghodegal, Ambaulim in cuncolim Constituency.

**SAMPLE SENT BY:** AE, SD III, WD XIV, WRD, Cuncolim- Goa.

**NAME OF THE AGENCY**

**TESTING PERIOD**

07 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
6.1	F.61/101/2021						115.56		No. WRD/SD III/WD XIV/ W.F.10/2021-22/212 <b>DATED:- 14-01-2022.</b>
	F.61/102/2021	10/1/2022	17-01-2022	Left side Abutment wall of slab culvert	1.2.4	100 kg/cm2	120.00	115.56	
	F.61/103/2021						111.11		
6.2	F.61/104/2021						115.56		do
	F.61/105/2021	10/1/2022	17-01-2022	Left side Abutment wall of slab culvert	1.2.4	100 kg/cm2	124.44	117.04	
	F.61/106/2021						111.11		
6.3	F.61/107/2021						120.00		do
	F.61/108/2021	10/1/2022	17-01-2022	Left side Abutment wall of slab culvert	1.2.4	100 kg/cm2	115.56	118.52	
	F.61/109/2021						120.00		
6.4	F.61/110/2021						120.00		do
	F.61/111/2021	10/1/2022	17-01-2022	Left side Abutment wall of slab culvert	1.2.4	100 kg/cm2	120.00	117.04	
	F.61/112/2021						111.11		
7.1	F.61/113/2021						115.56		No. WRD/SD III/WD XIV/ W.F.10/2021-22/214 <b>DATED:- 16-01-2022.</b>
	F.61/114/2021	11/1/2022	18-01-2022	RCC slab culvert abutment wall	1.2.4	100 kg/cm2	115.55	117.04	
	F.61/115/2021			right side			120.00		
7.2	F.61/116/2021						115.56		do
	F.61/117/2021	11/1/2022	18-01-2022	RCC slab culvert abutment wall	1.2.4	100 kg/cm2	124.44	117.04	
	F.61/118/2021			right side			111.11		
7.3	F.61/119/2021						120.00		do
	F.61/120/2021	11/1/2022	18-01-2022	RCC slab culvert abutment wall	1.2.4	100 kg/cm2	115.56	118.52	
	F.61/121/2021			right side			120.00		
8.1	F.61/122/2021						120.00		do
	F.61/123/2021	11/1/2022	18-01-2022	RCC slab culvert abutment wall	1.2.4	100 kg/cm2	120.00	117.04	
	F.61/124/2021			left side			111.11		

**JUNIOR ENGINEER.**

**ASSISTANT ENGINEER**

**GOVERNMENT OF GOA  
SD III (QC) , WRD, GOGAL, MARGAO- GOA.**

**NAME OF THE WORK:** Re- Construction of Pipe Culvert with RCC slab at Ghodegal, Ambaulim in cuncolim Constituency.

**SAMPLE SENT BY:** AE, SD III, WD XIV, WRD, Cuncolim- Goa.

NAME OF THE AGENCY				TESTING PERIOD		07 days.			
REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
8.2	F.61/125/2021						115.56		No. WRD/SD III/WD XIV/ W.F.10/2021-22/214 <b>DATED:- 16-01-2022.</b>
	F.61/126/2021	11/1/2022	18-01-2022	RCC slab culvert abutment wall	1.2.4	100 kg/cm2	120.00	118.52	
	F.61/127/2021			left side			120.00		
8.3	F.61/128/2021						115.56		do
	F.61/129/2021	11/1/2022	18-01-2022	RCC slab culvert abutment wall	1.2.4	100 kg/cm2	120.00	115.56	
	F.61/130/2021			left side			111.11		
9.1	F.61/131/2021						115.56		do
	F.61/132/2021	12/1/2022	19-01-2022	RCC slab culvert abutment wall	1.2.4	100 kg/cm2	124.44	117.04	
	F.61/133/2021			right side			111.11		
9.2	F.61/134/2021						120.00		do
	F.61/135/2021	12/1/2022	19-01-2022	RCC slab culvert abutment wall	1.2.4	100 kg/cm2	120.00	117.04	
	F.61/136/2021			right side			111.11		
9.3	F.61/137/2021						115.56		do
	F.61/138/2021	12/1/2022	19-01-2022	RCC slab culvert abutment wall	1.2.4	100 kg/cm2	115.55	117.04	
	F.61/139/2021			right side			120.00		
10.1	F.61/140/2021						115.56		do
	F.61/141/2021	12/1/2022	19-01-2022	RCC slab culvert abutment wall	1.2.4	100 kg/cm2	115.56	115.56	
	F.61/142/2021			left side			115.56		
10.2	F.61/143/2021						111.11		do
	F.61/144/2021	12/1/2022	19-01-2022	RCC slab culvert abutment wall	1.2.4	100 kg/cm2	115.56	115.56	
	F.61/145/2021			left side			120.00		
10.3	F.61/146/2021						115.56		do
	F.61/147/2021	12/1/2022	19-01-2022	RCC slab culvert abutment wall	1.2.4	100 kg/cm2	115.56	117.04	
	F.61/148/2021			left side			120.00		

**JUNIOR ENGINEER.**

**ASSISTANT ENGINEER**