## GOVERNMENT OF GOA QUALITY CONTROL LABORATORY WATER RESOURCES DEPARTMENT

Test Report No.: WRD / QC / F.6-2 / Cube -T :3838, 3850,3864 & 3879 / Lab /27 / 2022 - 23 Dated: - 12 / 04 / 2022.

Laboratory : Bicholim - Goa. Sub Division V (QC)/WRD/ Bicholim- Goa.

## Name of work: "Improvement and Development of Veling Talli at Talewada in Survey No. 22/0, of Veling Village in Priol Constituency.

Ref. to Requisition No.: WRD/WDXI/SDIV/W.F.464/537/21-22 Dated :- 24/03/2022.

Qty. Recived.: 04 Sets of cube Date of Receipt:- 06/ 04/ 2022. Tested on: 06,07,08 & 09/04/2022 as per due dates. Ref to CPWD::2009, Vol. I

Sample: Cube Mix PCC 1: 2: 4 O.S No.: 8040,8060,8083 & 8102/SS Lab. Sample No.: 3765 To 3768 Tested By: Mrs. S. B. Naik Shirodkar J.E.

## **REPORT PAGE 01 OF 01**

SR. NO	DISCRIPTION OF SAMPLE	TESTED FOR	RESULTS		Max./Min.Value permissable	% above or below	REMARK
1	Cement concrete cube of mix 1:2:4, cast on 09/03/2022. PCC for Side Wall.	28 <sup>th</sup> day	246.91	Kg/Cm <sup>2</sup>	210.00 Kg/cm <sup>2</sup>	12.54	Qty represents - 20.00 m3.
		compressive	235.59	Kg/Cm <sup>2</sup>			
		strength	226.53	Kg/Cm <sup>2</sup>			
		Average	236.34	Kg/Cm <sup>2</sup>			
2	Cement concrete cube of mix 1:2:4, cast on 10/03/2022. PCC for Side Wall.	28 <sup>th</sup> day	226.53	Kg/Cm <sup>2</sup>	210.00 Kg/cm <sup>2</sup>	9.31	Qty represents - 20.00 m3.
		compressive	244.65	Kg/Cm <sup>2</sup>			
		strenath	217.47	Kg/Cm <sup>2</sup>			
		Average	229.55	Kg/Cm <sup>2</sup>			
3	Cement concrete cube of mix 1:2:4, cast on 11/03/2022. PCC for Side Wall.	28 <sup>th</sup> day	219.73	Kg/Cm <sup>2</sup>	210.00 Kg/cm <sup>2</sup>	6.43	Qty represents - 20.00 m3.
		compressive	215.20	Kg/Cm <sup>2</sup>			
		strength	235.59	Kg/Cm <sup>2</sup>			
		Average	223.51	Kg/Cm <sup>2</sup>			
	Cement concrete cube of mix 1:2:4, cast on 12/03/2022. PCC for Side Wall.	28 <sup>th</sup> day	231.06	Kg/Cm <sup>2</sup>	210.00 Kg/cm <sup>2</sup>	10.75	Oty represents - 20.00 m3.
1		compressive	222.00	Kg/Cm <sup>2</sup>			
-		strenath	244.65	Kg/Cm <sup>2</sup>			
		Average	232.57	Kg/Cm <sup>2</sup>			

Copy to: 1. The Assistant Engineer , SD IV , WD XI, WRD, Ponda - Goa.

4. QC Lab File. 5. Bill File.

Junior Engineer

Assistant Engineer

<sup>2.</sup> Copy submitted to The Superintending Engineer ,CPO,WRD, Sinchai Bhavan, Porvorim Goa for kind Information.

<sup>3.</sup> Copy submitted to The Executive Engineer, WD XI, WRD, Ravonfond, Navelim, Salcete - Goa.