

GOVERNMENT OF GOA
QUALITY CONTROL LABORATORY
WATER RESOURCES DEPARTMENT

Test Report No.: WRD / QC / F.6-2 / Cube -T :3239/ Lab /311 / 2021 - 22 Dated:- 24 /02/ 2022.

Laboratory : Bicholim - Goa.
Sub Division V (QC)/WRD/ Bicholim- Goa.

Name of work : Improvement to Kodo Katar along the bank of Chapora river at camurlim in Tivim Constituency.

Ref. to Requisition No.: WRD/SDV/QC/WDVIII/F.3-9/2021-22/337(QC Programme) Dt.:-16/ 02/ 2022

Qty. Recived. : 01 Set of cube Date of Receipt:- 16/ 02 / 2022. Tested on: 23/02/2022 as per due dates. Ref to CPWD :2009, Vol. I

Sample: Cube Mix PCC - 1:2:4 O.S No. :7736/SS Lab. Sample No.: 3042 Tested By: Mrs.Shirodkar. J.E.

REPORT PAGE 01 OF 01

SR. NO	DISCRIPTION OF SAMPLE	TESTED FOR	RESULTS		Max./Min. Value permissible	% above or below	REMARK
1	Cement concrete cube of mix PCC - 1:2:4 , cast on 16/02/2022(Cubes were casted during site inspection by Q.C.Officials at site in the presence of Departmental Engineers and repressentative by agency M/s. Jeni Associates, civil contractor, Engineerings Services Pvt. Ltd.)	07 th day compressive strength	181.22	Kg/Cm ²	140.00 Kg/cm ²	21.89	28th day test due on 16/03/2022.
			158.57	Kg/Cm ²			
			172.16	Kg/Cm ²			
		Average	170.65	Kg/Cm²			

Copy to: 1. The Assistant Engineer , SDII , WDI, WRD, Mapusa - Goa.

2. Copy submitted to The Superintending Engineer ,CPO,WRD, Sinchai Bhavan, Porvorim Goa for kind Information.

3. Copy submitted to The Executive Engineer , WD VIII ,WRD, Karaswada-Bardez- Goa.

4. QC Lab File. 5. Bill File.

Junior Engineer

Assistant Engineer