

GOVERNMENT OF GOA  
QUALITY CONTROL LABORATORY  
WATER RESOURCES DEPARTMENT

Test Report No.: WRD / QC / F.6-2 / Cube -T :3254/ Lab /315 / 2021 - 22 Dated:- 26 /02/ 2022.

Laboratory : Bicholim - Goa.

Sub Division V (QC)/WRD/ Bicholim- Goa.

**Name of work : Construction of protection wall for Nalla from Shri Amrut Pednekar House to Kishore Patil House at Chinch – Bhatwadi, Mayem in Sy. No. 185 of Bicholim Taluka.**

Ref. to Requisition No.: WRD/SDV/QC/WDVIII/F.3-9/2021-22/338(QC Programme) Dt.:-18/ 02/ 2022

Qty. Received. : 01 Set of cube Date of Receipt:- 18/ 02 / 2022. Tested on: 25/02/2022 as per due dates. Ref to CPWD :2009, Vol. I

Sample: Cube Mix PCC - 1:2:4 O.S No. :7751/SS Lab. Sample No.: 3045 Tested By: Mrs.Shirodkar. J.E.

**REPORT PAGE 01 OF 01**

SR. NO	DISCRIPTION OF SAMPLE	TESTED FOR	RESULTS		Max./Min. Value permissible	% above or below	REMARK
1	Cement concrete cube of mix PCC - 1:2:4 , cast on 18/02/2022(Cubes were casted during site inspection by Q.C.Officials at site in the presence of Departmental Engineers and representative by agency M/s. Cherkala Constructions, Panditwada, Ponda Goa, civil contractor, Engineerings Services Pvt. Ltd.)	07 <sup>th</sup> day compressive strength	135.92	Kg/Cm <sup>2</sup>	140.00 Kg/cm <sup>2</sup>	7.33	28th day test due on 18/03/2022.
			160.83	Kg/Cm <sup>2</sup>			
			154.04	Kg/Cm <sup>2</sup>			
		<b>Average</b>	<b>150.26</b>	<b>Kg/Cm<sup>2</sup></b>			

Copy to: 1. The Assistant Engineer , SDI, WDV, WRD, Bicholim - Goa.

2. Copy submitted to The Superintending Engineer ,CPO,WRD, Sinchai Bhavan, Porvorim Goa for kind Information.

3. Copy submitted to The Executive Engineer , WD VI ,WRD, Bicholim - Goa.

4. QC Lab File. 5. Bill File.

Junior Engineer

Assistant Engineer