

GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Construction of Retaining wall to protect the flood affected nallah bank of Aadi nallah at Poinguinim in Canacona Taluka.

SAMPLE SENT BY: AE, SD I, WD XI, WRD, Canacona- Goa.

NAME OF THE AGENCY				TESTING PERIOD		28 days.			
REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
1.1	92						173.33		No. WRD/ WD XI/ SD I/ F.175/149/2020-21. DATED: 27-11-2020
	93	23-11-2020	21-12-2020	Retaining wall left side foundation	1.2.4	150 kg/cm2	173.33	173.33	
	94			Concrete from Ch. 50.00 to 68.00			173.33		
1.2	95						173.33		
	96	23-11-2020	21-12-2020	Retaining wall left side foundation	1.2.4	150 kg/cm2	168.89	171.85	do
	97			Concrete from Ch. 50.00 to 68.00			173.33		
2.1	98						173.33		
	99	24-11-2020	22-12-2020	Retaining wall left side foundation	1.2.4	150 kg/cm2	173.33	171.85	do
	100			Concrete from Ch. 68.00 to 86.00			168.89		
2.2	101						173.33		
	102	24-11-2020	22-12-2020	Retaining wall left side foundation	1.2.4	150 kg/cm2	173.33	173.33	do
	103			Concrete from Ch. 68.00 to 86.00			173.33		
3.1	104						164.44		
	105	25-11-2020	23-12-2020	Retaining wall left side foundation	1.2.4	150 kg/cm2	168.89	167.41	do
	106			Concrete from Ch. 86.00 to 104.00			168.89		
3.2	107						173.33		
	108	25-11-2020	23-12-2020	Retaining wall left side foundation	1.2.4	150 kg/cm2	168.89	170.37	do
	109			Concrete from Ch. 86.00 to 104.00			168.89		
4.1	110						173.33		
	111	26-11-2020	24-12-2020	Retaining wall left side foundation	1.2.4	150 kg/cm2	173.33	171.85	do
	112			Concrete from Ch. 104.00 to 122.00			168.89		
4.2	113						168.89		
	114	26-11-2020	24-12-2020	Retaining wall left side foundation	1.2.4	150 kg/cm2	168.89	170.37	do
	115			Concrete from Ch. 104.00 to 122.00			173.33		

JUNIOR ENGINEER.

ASSISTANT ENGINEER

GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Construction of Retaining wall to protect the flood affected nallah bank of Aadi nallah at Poinguinim in Canacona Taluka.

SAMPLE SENT BY: AE, SD I, WD XI, WRD, Canacona- Goa.

NAME OF THE AGENCY				TESTING PERIOD		28 days.			
REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
5.1	266						168.89		No. WRD/ WD XI/ SD I/
	267	27-11-2020	26-12-2020	Retaining wall left side foundation	1.2.4	150 kg/cm2	173.33	171.85	F.175/154/2020-21.
	268			Concrete from Ch. 122.00 to 140.00			173.33		DATED: 04-12-2020
5.2	269						173.33		
	270	27-11-2020	26-12-2020	Retaining wall left side foundation	1.2.4	150 kg/cm2	168.89	171.85	do
	271			Concrete from Ch. 122.00 to 140.00			173.33		
6.1	272						177.78		
	273	28-11-2020	26-12-2020	Retaining wall 1st lift left side	1.2.4	150 kg/cm2	177.78	176.30	do
	274			Concrete from Ch. 50.00 to 80.00			173.33		
6.2	275						182.22		
	276	28-11-2020	26-12-2020	Retaining wall 1st lift left side	1.2.4	150 kg/cm2	177.78	179.26	do
	277			Concrete from Ch. 50.00 to 80.00			177.78		
7.1	278						182.22		
	279	30-11-2020	28-12-2020	Retaining wall 1st lift left side	1.2.4	150 kg/cm2	182.22	180.74	do
	280			Concrete from Ch. 80.00 to 110.00			177.78		
7.2	281						182.22		
	282	30-11-2020	28-12-2020	Retaining wall 1st lift left side	1.2.4	150 kg/cm2	177.78	180.74	do
	283			Concrete from Ch. 80.00 to 110.00			182.22		
8.1	284						177.78		
	285	1/12/2020	29-12-2020	Retaining wall 2nd lift left side	1.2.4	150 kg/cm2	182.22	179.26	do
	286			Concrete from Ch. 50.00 to 90.00			177.78		
8.2	287						182.22		
	288	1/12/2020	29-12-2020	Retaining wall 2nd lift left side	1.2.4	150 kg/cm2	182.22	180.74	do
	289			Concrete from Ch. 50.00 to 90.00			177.78		

JUNIOR ENGINEER.

ASSISTANT ENGINEER

GOVERNMENT OF GOA

SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Construction of Retaining wall to protect the flood affected nallah bank of Aadi nallah at Poinguinim in Canacona Taluka.

SAMPLE SENT BY: AE, SD I, WD XI, WRD, Canacona- Goa.

NAME OF THE AGENCY

TESTING PERIOD

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
9.1	218						173.33		No. WRD/ WD XI/ SD I/
	219	3/12/2020	31-12-2020	left side Retaining wall foundation	1.2.4	150 kg/cm2	177.78	176.30	F.175/164/2020-21.
	220			Concrete for Ch. 140.00 to 150.00 Mt			177.78		DATED: 10-12-2020
9.2	221						177.78		
	222	3/12/2020	31-12-2020	left side Retaining wall foundation	1.2.4	150 kg/cm2	177.78	177.78	do
	223			Concrete for Ch. 140.00 to 150.00 Mt			177.78		
10.1	224						173.33		
	225	4/12/2020	1/1/2021	left side Retaining wall 1st lift	1.2.4	150 kg/cm2	177.78	174.81	do
	226			Concrete for Ch. 110.00 to 140.00 Mt			173.33		
10.2	227						173.33		
	228	4/12/2020	1/1/2021	left side Retaining wall 1st lift	1.2.4	150 kg/cm2	177.78	176.30	do
	229			Concrete for Ch. 110.00 to 140.00 Mt			177.78		
11.1	230						177.78		
	231	5/12/2020	2/1/2021	left side Retaining wall 2nd lift	1.2.4	150 kg/cm2	173.33	176.30	do
	232			Concrete for Ch. 90.00 to 130.00 Mt			177.78		
11.2	233						173.88		
	234	5/12/2020	2/1/2021	left side Retaining wall 2nd lift	1.2.4	150 kg/cm2	173.33	175.00	do
	235			Concrete for Ch. 90.00 to 130.00 Mt			177.78		
12.1	236			left side Retaining wall 3rd lift concrete			173.33		
	237	7/12/2020	4/1/2021	for Ch. 50.00 to 100.00 & left side 1st lift	1.2.4	150 kg/cm2	177.78	176.30	do
	238			concrete from Ch. 140.00 to 150.00			177.78		
12.2	239			left side Retaining wall 3rd lift concrete			173.33		
	240	7/12/2020	4/1/2021	for Ch. 50.00 to 100.00 & left side 1st lift	1.2.4	150 kg/cm2	177.78	174.81	do
	241			concrete from Ch. 140.00 to 150.00			173.33		

JUNIOR ENGINEER.

ASSISTANT ENGINEER

GOVERNMENT OF GOA

SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Construction of Retaining wall to protect the flood affected nallah bank of Aadi nallah at Poinguinim in Canacona Taluka.

SAMPLE SENT BY: AE, SD I, WD XI, WRD, Canacona- Goa.

NAME OF THE AGENCY

TESTING PERIOD

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
13.1	497						173.33		No. WRD/ WD XI/ SD I/ F.175/169/2020-21. DATED: 15-12-2020
	498	8/12/2020	5/1/2021	Right side Retaining wall foundation	1.2.4	150 kg/cm2	177.78	177.78	
	499			Concrete from Ch. 55.00 to 80.00 Mt			182.22		
13.2	500						177.78		
	501	8/12/2020	5/1/2021	Right side Retaining wall foundation	1.2.4	150 kg/cm2	177.78	179.26	do
	502			Concrete from Ch. 55.00 to 80.00 Mt			182.22		
13.3	503						182.22		
	504	8/12/2020	5/1/2021	Right side Retaining wall foundation	1.2.4	150 kg/cm2	177.78	180.74	do
	505			Concrete from Ch. 55.00 to 80.00 Mt			182.22		
14.1	506						177.78		
	507	9/12/2020	6/1/2021	Right side Retaining wall foundation	1.2.4	150 kg/cm2	177.78	176.30	do
	508			Concrete from Ch. 80.00 to 105.00 Mt			173.33		
14.2	509						177.78		
	510	9/12/2020	6/1/2021	Right side Retaining wall foundation	1.2.4	150 kg/cm2	173.33	174.81	do
	511			Concrete from Ch. 80.00 to 105.00 Mt			173.33		
14.3	512						177.78		
	513	9/12/2020	6/1/2021	Right side Retaining wall foundation	1.2.4	150 kg/cm2	177.78	176.30	do
	514			Concrete from Ch. 80.00 to 105.00 Mt			173.33		
15.1	515						177.78		
	516	10/12/2020	7/1/2021	Right side Retaining wall 1st lift	1.2.4	150 kg/cm2	182.22	179.26	do
	517			Concrete from Ch. 55.00 to 100.00 Mt			177.78		
15.2	518						182.22		
	519	10/12/2020	7/1/2021	Right side Retaining wall 1st lift	1.2.4	150 kg/cm2	177.78	179.26	do
	520			Concrete from Ch. 55.00 to 100.00 Mt			177.78		

JUNIOR ENGINEER.

ASSISTANT ENGINEER

GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Construction of Retaining wall to protect the flood affected nallah bank of Aadi nallah at Poinguinim in Canacona Taluka.

SAMPLE SENT BY: AE, SD I, WD XI, WRD, Canacona- Goa.

NAME OF THE AGENCY

TESTING PERIOD

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
15.3	521						177.78		No. WRD/ WD XI/ SD I/
	522	10/12/2020	7/1/2021	Right side Retaining wall 1st lift	1.2.4	150 kg/cm2	177.78	177.78	F.175/169/2020-21.
	523			Concrete from Ch. 55.00 to 100.00 Mt			177.78		DATED: 15-12-2020
16.1	524						164.44		
	525	14-12-2020	11/1/2021	Right side Retaining wall 2nd lift	1.2.4	150 kg/cm2	168.89	165.92	do
	526			Concrete from Ch. 55.00 to 95.00 Mt			164.44		
16.2	527						168.89		
	528	14-12-2020	11/1/2021	Right side Retaining wall 2nd lift	1.2.4	150 kg/cm2	168.89	168.89	do
	529			Concrete from Ch. 55.00 to 95.00 Mt			168.89		
17.1	542						177.78		No. WRD/ WD XI/ SD I/
	543	15-12-2020	12/1/2021	Left side Retaining wall 2nd	1.2.4	150 kg/cm2	177.78	177.78	F.175/173/2020-21.
	544			Concrete from Ch. 130.00 to 150.00 Mt			177.78		DATED: 22-12-2020
17.2	545						164.44		
	546	15-12-2020	12/1/2021	Left side Retaining wall 2nd	1.2.4	150 kg/cm2	168.89	165.92	do
	547			Concrete from Ch. 130.00 to 150.00 Mt			164.44		
18.1	548						168.89		
	549	16-12-2020	13-01-2021	Right side Retaining wall foundation	1.2.4	150 kg/cm2	168.89	168.89	do
	550			Concrete from Ch. 105.00 to 115.00 Mt			168.89		
18.2	551						164.44		
	552	16-12-2020	13-01-2021	Right side Retaining wall foundation	1.2.4	150 kg/cm2	168.89	165.92	do
	553			Concrete from Ch. 105.00 to 115.00 Mt			164.44		
19.1	623						173.33		No. WRD/ WD XI/ SD I/
	624	21-12-2020	18-01-2021	Right side Retaining wall foundation	1.2.4	150 kg/cm2	173.33	171.85	F.175/178/2020-21.
	625			Concrete from Ch. 115.00 to 133.00 Mt			168.89		DATED: 28-12-2020

JUNIOR ENGINEER.

ASSISTANT ENGINEER

GOVERNMENT OF GOA

SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Construction of Retaining wall to protect the flood affected nallah bank of Aadi nallah at Poinguinim in Canacona Taluka.

SAMPLE SENT BY: AE, SD I, WD XI, WRD, Canacona- Goa.

NAME OF THE AGENCY

TESTING PERIOD

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
19.2	626						173.33		No. WRD/ WD XI/ SD I/ F.175/178/2020-21. DATED: 28-12-2020
	627	21-12-2020	18-01-2021	Right side Retaining wall foundation	1.2.4	150 kg/cm2	168.89	170.37	
	628			Concrete from Ch. 115.00 to 133.00 Mt			168.89		
20.1	629						164.44		
	630	22-12-2020	19-01-2021	Right side 1st lift concrete from	1.2.4	150 kg/cm2	164.44	162.96	do
	631			Ch. 100.00 to 130.00 Mt			160.00		
20.2	632						164.44		
	633	22-12-2020	19-01-2021	Right side 1st lift concrete from	1.2.4	150 kg/cm2	160.00	162.96	do
	634			Ch. 100.00 to 130.00 Mt			164.44		
21.1	635						173.33		
	636	23-12-2020	20-01-2021	Right side 2nd lift concrete from	1.2.4	150 kg/cm2	173.33	171.85	do
	637			Ch. 95.00 to 130.00 Mt			168.89		
21.2	638						168.89		
	639	23-12-2020	20-01-2021	Right side 2nd lift concrete from	1.2.4	150 kg/cm2	173.33	171.85	do
	640			Ch. 95.00 to 130.00 Mt			173.33		
22.1	641						177.78		
	642	24-12-2020	21-01-2021	Left side Retaining wall foundation	1.2.4	150 kg/cm2	173.33	176.30	do
	643			Concrete from Ch. 50.00 to 25.00 Mt			177.78		
22.2	644						177.78		
	645	24-12-2020	21-01-2021	Left side Retaining wall foundation	1.2.4	150 kg/cm2	177.78	176.30	do
	646			Concrete from Ch. 50.00 to 25.00 Mt			173.33		
22.3	647						177.78		
	648	24-12-2020	21-01-2021	Left side Retaining wall foundation	1.2.4	150 kg/cm2	173.33	176.30	do
	649			Concrete from Ch. 50.00 to 25.00 Mt			177.78		

JUNIOR ENGINEER.

ASSISTANT ENGINEER

GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Construction of Retaining wall to protect the flood affected nallah bank of Aadi nallah at Poinguinim in Canacona Taluka.

SAMPLE SENT BY: AE, SD I, WD XI, WRD, Canacona- Goa.

NAME OF THE AGENCY

TESTING PERIOD

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
23.1	650						173.33		No. WRD/ WD XI/ SD I/ F.175/178/2020-21. DATED: 28-12-2020
	651	26-12-2020	23-01-2021	Left side Retaining wall 1st lift	1.2.4	150 kg/cm2	173.33	174.81	
	652			Concrete from Ch. 50.00 to 25.00 Mt			177.78		
23.2	653						173.33		
	654	26-12-2020	23-01-2021	Left side Retaining wall 1st lift	1.2.4	150 kg/cm2	173.33	173.33	do
	655			Concrete from Ch. 50.00 to 25.00 Mt			173.33		
24.1	707						177.78		No. WRD/ WD XI/ SD I/ F.175/183/2020-21. DATED: 04-01-2021
	708	29-12-2020	26-01-2021	Right side Retaining wall foundation	1.2.4	150 kg/cm2	182.22	179.26	
	709			Concrete from Ch. 0.00 to 18.00 mt			177.78		
24.2	710						177.78		
	711	29-12-2020	26-01-2021	Right side Retaining wall foundation	1.2.4	150 kg/cm2	177.78	179.26	do
	712			Concrete from Ch. 0.00 to 18.00 mt			182.22		
25.1	713						177.78		
	714	30-12-2020	27-01-2021	Right side Retaining wall foundation	1.2.4	150 kg/cm2	177.78	176.30	do
	715			concrete from Ch. 18.00 to 36.00 Mt			173.33		
25.2	716						173.33		
	717	30-12-2020	27-01-2021	Right side Retaining wall foundation	1.2.4	150 kg/cm2	177.75	174.80	do
	718			concrete from Ch. 18.00 to 36.00 Mt			173.33		
26.1	719						177.78		
	720	31-12-2020	28-01-2021	Right side Retaining wall foundation	1.2.4	150 kg/cm2	182.22	179.26	do
	721			Concrete from Ch. 36.00 to 55.00 Mt			177.78		
26.2	722						177.78		
	723	31-12-2020	28-01-2021	Right side Retaining wall foundation	1.2.4	150 kg/cm2	177.78	176.30	do
	724			Concrete from Ch. 36.00 to 55.00 Mt			173.33		

JUNIOR ENGINEER.

ASSISTANT ENGINEER

GOVERNMENT OF GOA

SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Construction of Retaining wall to protect the flood affected nallah bank of Aadi nallah at Poinguinim in Canacona Taluka.

SAMPLE SENT BY: AE, SD I, WD XI, WRD, Canacona- Goa.

NAME OF THE AGENCY					TESTING PERIOD		28 days.		
REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
27.1	725						177.78		No. WRD/ WD XI/ SD I/ F.175/183/2020-21. DATED: 04-01-2021
	726	1/1/2021	29-01-2021	Right side retaining wall 1st lift	1.2.4	150 kg/cm2	177.78	176.30	
	727			Concrete from Ch. 0.00 to 15.00 Mt			173.33		
28.1	995						168.89		No. WRD/ WD XI/ SD I/ F.175/189/2020-21. DATED: 08-01-2021
	996	4/1/2021	1/2/2021	Right side Retaining wall Ist lift	1.2.4	150 kg/cm2	173.33	171.85	
	997			Concrete from Ch. 15.00 to 55.00 Mt			173.33		
28.2	998						173.33		do
	999	4/1/2021	1/2/2021	Right side Retaining wall Ist lift	1.2.4	150 kg/cm2	173.33	171.85	
	1000			Concrete from Ch. 15.00 to 55.00 Mt			168.89		
28.3	1001						168.89		do
	1002	4/1/2021	1/2/2021	Right side Retaining wall Ist lift	1.2.4	150 kg/cm2	173.33	170.37	
	1003			Concrete from Ch. 15.00 to 55.00 Mt			168.89		
29.1	1004						173.33		do
	1005	5/1/2021	2/2/2021	Right side Retaining wall II nd lift	1.2.4	150 kg/cm2	173.33	174.81	
	1006			Concrete from Ch.0.00 to 25.00 Mt			177.78		
29.2	1007						177.78		do
	1008	5/1/2021	2/2/2021	Right side Retaining wall II nd lift	1.2.4	150 kg/cm2	173.33	176.30	
	1009			Concrete from Ch.0.00 to 25.00 Mt			177.78		
30.1	1010						160.00		do
	1011	6/1/2021	3/2/2021	Right side Retaining wall II nd Lift	1.2.4	150 kg/cm2	164.44	161.48	
	1012			concrete from Ch. 25.00 to 55.00 Mt			160.00		
30.2	1013						164.44		do
	1014	6/1/2021	3/2/2021	Right side Retaining wall II nd Lift	1.2.4	150 kg/cm2	164.44	162.96	
	1015			concrete from Ch. 25.00 to 55.00 Mt			160.00		

JUNIOR ENGINEER.

ASSISTANT ENGINEER

GOVERNMENT OF GOA

SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Construction of Retaining wall to protect the flood affected nallah bank of Aadi nallah at Poinguinim in Canacona Taluka

SAMPLE SENT BY: AE, SD I, WD XI, WRD, Canacona- Goa.

NAME OF THE AGENCY					TESTING PERIOD		28 days.		
REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
31.1	1085						168.89		No. WRD/ WD XI/ SD I/ F.175/194/2020-21. DATED: 14-01-2021
	1086	8/1/2021	5/2/2021	Left side retaining wall foundation	1.2.4	150 kg/cm2	168.89	167.41	
	1087			Concrete from Ch. 25.00 to 7.00 Mt			164.44		
31.2	1088						164.44		
	1089	8/1/2021	5/2/2021	Left side retaining wall foundation	1.2.4	150 kg/cm2	164.44	165.92	do
	1090			Concrete from Ch. 25.00 to 7.00 Mt			168.89		
32.1	1091						164.44		
	1092	9/1/2021	6/2/2021	Left side Retaining wall Ist lift	1.2.4	150 kg/cm2	168.89	165.92	do
	1093			Concrete from Ch. 25.00 to 10.00 Mt			164.44		
32.2	1094						164.44		
	1095	9/1/2021	6/2/2021	Left side Retaining wall Ist lift	1.2.4	150 kg/cm2	164.44	162.96	do
	1096			Concrete from Ch. 25.00 to 10.00 Mt			160.00		
33.1	1097						164.44		
	1098	11/1/2021	8/2/2021	Left side Retaining wall II nd lift	1.2.4	150 kg/cm2	160.00	164.44	do
	1099			Concrete from Ch.50.00 to 13.00 Mt			168.89		
33.2	1100						164.44		
	1101	11/1/2021	8/2/2021	Left side Retaining wall II nd lift	1.2.4	150 kg/cm2	164.44	162.96	do
	1102			Concrete from Ch.50.00 to 13.00 Mt			160.00		
34	1103						168.89		
	1104	12/1/2021	9/2/2021	Left side Retaining wall III rd Lift	1.2.4	150 kg/cm2	164.44	165.92	do
	1105			concrete from Ch. 50.00 to 15.00 Mt			164.44		

JUNIOR ENGINEER.

ASSISTANT ENGINEER

GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Construction of Retaining wall to protect the flood affected nallah bank of Aadi nallah at Poinguinim in Canacona Taluka.

SAMPLE SENT BY: AE, SD I, WD XI, WRD, Canacona- Goa.

NAME OF THE AGENCY

TESTING PERIOD

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
35.1	1223						168.89		No. WRD/ WD XI/ SD I/
	1224	15-01-2021	12/2/2021	Right side Retaining wall IIIrd lift	1.2.4	150 kg/cm2	164.44	164.44	F.175/201/2020-21.
	1225			Concrete from Ch. 0.00 to 50.00 Mt			160.00		DATED: 21-01-2021
35.2	1226						168.89		
	1227	15-01-2021	12/2/2021	Right side Retaining wall IIIrd lift	1.2.4	150 kg/cm2	164.44	165.92	do
	1228			Concrete from Ch. 0.00 to 50.00 Mt			164.44		
36.1	1229						151.11		
	1230	16-01-2021	13-02-2021	Right side Retaining wall IIIrd lift	1.2.4	150 kg/cm2	160.00	157.04	
	1231			Concrete from Ch.50.00 to 100.00 Mt			160.00		
36.2	1232						160.00		
	1233	16-01-2021	13-02-2021	Right side Retaining wall IIIrd lift	1.2.4	150 kg/cm2	155.56	158.52	do
	1234			Concrete from Ch.50.00 to 100.00 Mt			160.00		
37.1	1235						164.44		
	1236	18-01-2021	15-02-2021	Left side Retaining wall foundation	1.2.4	150 kg/cm2	168.89	165.92	do
	1237			concrete from Ch. 0.00 to 7.00 Mt			164.44		
37.2	1238						164.44		
	1239	18-01-2021	15-02-2021	Left side Retaining wall foundation	1.2.4	150 kg/cm2	168.89	165.92	do
	1240			concrete from Ch. 0.00 to 7.00 Mt			164.44		
38	1241						168.89		
	1242	19-01-2021	16-02-2021	Left side Retaining wall 1st Lift	1.2.4	150 kg/cm2	164.44	167.41	do
	1243			Concrete from Ch. 0.00 to 10.00 Mt			168.89		

JUNIOR ENGINEER.

ASSISTANT ENGINEER

GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Construction of Retaining wall to protect the flood affected nallah bank of Aadi nallah at Poinguinim in Canacona Taluka.

SAMPLE SENT BY: AE, SD I, WD XI, WRD, Canacona- Goa.

NAME OF THE AGENCY				TESTING PERIOD		28 days.			
REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
39.1	1316			Right side Retaining wall foundation			164.44		No. WRD/ WD XI/ SD I/ F.175/207/2020-21. DATED: 27-01-2021
	1317	21-01-2021	18-02-2021	concrete from Ch. 133.00 to 145.00 Mt	1.2.4	150 kg/cm2	168.89	165.92	
	1318						164.44		
39.2	1319			Right side Retaining wall foundation			164.44		
	1320	21-01-2021	18-02-2021	concrete from Ch. 133.00 to 145.00 Mt	1.2.4	150 kg/cm2	168.89	165.92	do
	1321						164.44		
40.1	1322			Right side retaining wall 1st lift concrete from Ch. 130.00 to 145 .00 mt & Left side retaining wall lind lift concrete from Ch. 0.00 to 13.00 mt			168.89		
	1323	22-01-2021	19-02-2021		1.2.4	150 kg/cm2	164.44	167.41	do
	1324						168.89		
40.2	1325						168.89		
	1326	22-01-2021	19-02-2021		1.2.4	150 kg/cm2	168.89	167.41	do
	1327						164.44		
41.1	1328			Left side Retaining wall Illrd lift concrete for Ch. 0.00 to 15.00 mt & Right side Illrd Lift for Ch. 100.00 to 130.00			173.33		
	1329	23-01-2021	20-02-2021		1.2.4	150 kg/cm2	173.33	171.85	do
	1330						168.89		
41.2	1331						173.33		
	1332	23-01-2021	20-02-2021		1.2.4	150 kg/cm2	168.89	171.85	do
	1333						173.33		
42.1	1736			Left side Retaining wall foundation concrete from Ch. 150.00 to 165.00 mt & right side retaining wall foundation concrete from Ch. 145.00 to 150.00 mt stretch			160.00		No. WRD/ WD XI/ SD I/ F.175/213/2020-21. DATED: 01-02-2021
	1737	27-01-2021	24-02-2021		1.2.4	150 kg/cm2	164.44	162.96	
	1738						164.44		
42.2	1739						160.00		
	1740	27-01-2021	24-02-2021		1.2.4	150 kg/cm2	160.00	161.48	do
	1741						164.44		

JUNIOR ENGINEER.

ASSISTANT ENGINEER

GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Construction of Retaining wall to protect the flood affected nallah bank of Aadi nallah at Poinguinim in Canacona Taluka.

SAMPLE SENT BY: AE, SD I, WD XI, WRD, Canacona- Goa.

NAME OF THE AGENCY

TESTING PERIOD

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
43.1	1742			Left side Retaining wall 1st lift concrete from Ch. 150.00 to 165.00 mt & right side retaining wall 1st lift concrete from ch. 145.00 to 150.00 mt stretch			164.44		No. WRD/ WD XI/ SD I/
	1743	28-01-2021	25-02-2021		1.2.4	150 kg/cm2	164.44	165.92	F.175/213/2020-21.
	1744						168.89		DATED: 01-02-2021
43.2	1745						164.44		
	1746	28-01-2021	25-02-2021		1.2.4	150 kg/cm2	168.89	165.92	do
	1747						164.44		
44	1748			Left side Retaining wall IIInd lift concrete			173.33		
	1749	29-01-2021	26-02-2021	from Ch. 150.00 to 165.00 mt.	1.2.4	150 kg/cm2	168.89	170.37	do
	1750						168.89		
45	1751			Left side retaining wall IIIrd lift concrete			168.89		
	1752	30-01-2021	27-02-2021	from Ch. 150.00 to 165.00 mt. & left side	1.2.4	150 kg/cm2	168.89	168.89	do
	1753			concreting steps from Ch. 0 to 2.00 mt			168.89		
46	1784						173.33		No. WRD/ WD XI/ SD I/
	1785	4/2/2021	4/3/2021	Right side retaining wall II nd lift concrete	1.2.4	150 kg/cm2	168.89	170.37	F.175/223/2020-21.
	1786			from Ch. 130.00 to 150.00 mt stretch.			168.89		DATED: 10-02-2021
47	1787						168.89		
	1788	5/2/2021	5/3/2021	Right side Retaining wall IIIrd lift concrete	1.2.4	150 kg/cm2	168.89	168.89	do
	1789			from Ch. 130.00 to 150.00 mt stretch.			168.89		

JUNIOR ENGINEER.

ASSISTANT ENGINEER