

GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Construction of protection wall to the side bank of nallah at Rawabhat Shirvoi in ward No. 2 in Quepem Constituency.

SAMPLE SENT BY: AE, SD V, WD XII, WRD, Quepem- Goa.

NAME OF THE AGENCY				TESTING PERIOD		28 days.			
REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
1.1	1105						168.89		No. WRD/ WD XII/ SD V/ F.15/182/2020-21. DATED: 27-01-2021
	1106	15-01-2021	12/2/2021	Foundation	1.2.4	150 kg/cm2	168.89	170.37	
	1107						173.33		
1.2	1108						164.44		
	1109	15-01-2021	12/2/2021	Foundation	1.2.4	150 kg/cm2	168.89	167.41	do
	1110						168.89		
1.3	1111						164.44		
	1112	15-01-2021	12/2/2021	Foundation	1.2.4	150 kg/cm2	168.89	167.41	do
	1113						168.89		
1.4	1114						168.89		
	1115	15-01-2021	12/2/2021	Foundation	1.2.4	150 kg/cm2	168.89	167.41	do
	1116						164.44		
1.5	1117						173.33		
	1118	15-01-2021	12/2/2021	Foundation	1.2.4	150 kg/cm2	164.44	168.89	do
	1119						168.89		
1.6	1120						168.89		
	1121	15-01-2021	12/2/2021	Foundation	1.2.4	150 kg/cm2	168.89	167.41	do
	1122						164.44		
2.1	1123						164.44		
	1124	16-01-2021	13-02-2021	1st Lift	1.2.4	150 kg/cm2	164.44	165.92	do
	1125						168.89		
2.2	1126						168.89		
	1127	16-01-2021	13-02-2021	1st Lift	1.2.4	150 kg/cm2	164.44	167.41	do
	1128						168.89		

JUNIOR ENGINEER.

ASSISTANT ENGINEER

GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Construction of protection wall to the side bank of nallah at Rawabhat Shirvoi in ward No. 2 in Quepem Constituency.

SAMPLE SENT BY: AE, SD V, WD XII, WRD, Quepem- Goa.

NAME OF THE AGENCY				TESTING PERIOD		28 days.			
REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
2.3	1129						160.00		No. WRD/ WD XII/ SD V/ F.15/182/2020-21. DATED: 27-01-2021
	1130	16-01-2021	13-02-2021	1st Lift	1.2.4	150 kg/cm2	168.89	164.44	
	1131						164.44		
2.4	1132						164.44		
	1133	16-01-2021	13-02-2021	1st Lift	1.2.4	150 kg/cm2	164.44	162.96	do
	1134						160.00		
3.1	1135						168.89		
	1136	18-01-2021	15-02-2021	2nd Lift	1.2.4	150 kg/cm2	164.44	167.41	do
	1137						168.89		
3.2	1138						164.44		
	1139	18-01-2021	15-02-2021	2nd Lift	1.2.4	150 kg/cm2	168.89	167.41	do
	1140						168.89		
3.3	1141						168.89		
	1142	18-01-2021	15-02-2021	2nd Lift	1.2.4	150 kg/cm2	173.33	168.89	do
	1143						164.44		
3.4	1144						164.44		
	1145	18-01-2021	15-02-2021	2nd Lift	1.2.4	150 kg/cm2	164.44	167.40	do
	1146						173.33		
4.1	1147						164.44		
	1148	19-01-2021	16-02-2021	4th Lift	1.2.4	150 kg/cm2	160.00	162.96	do
	1149						164.44		
4.2	1150						164.44		
	1151	19-01-2021	16-02-2021	4th Lift	1.2.4	150 kg/cm2	164.44	165.92	do
	1152						168.89		

JUNIOR ENGINEER.

ASSISTANT ENGINEER

GOVERNMENT OF GOA

SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Construction of protection wall to the side bank of nallah at Rawabhat Shirvoi in ward No. 2 in Quepem Constituency.

SAMPLE SENT BY: AE, SD V, WD XII, WRD, Quepem- Goa.

NAME OF THE AGENCY

TESTING PERIOD

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
5.1	1153						164.44		No. WRD/ WD XII/ SD V/ F.15/182/2020-21. DATED: 27-01-2021
	1154	20-01-2021	17-02-2021	4th Lift	1.2.4	150 kg/cm2	168.89	165.92	
	1155						164.44		
5.2	1156						168.89		
	1157	20-01-2021	17-02-2021	4th Lift	1.2.4	150 kg/cm2	168.89	168.89	do
	1158						168.89		
6.1	1159						168.89		
	1160	21-01-2021	18-02-2021	4th Lift	1.2.4	150 kg/cm2	164.44	167.41	do
	1161						168.89		
6.2	1162						168.89		
	1163	21-01-2021	18-02-2021	4th Lift	1.2.4	150 kg/cm2	168.89	168.89	do
	1164						168.89		
7.1	1165						168.89		
	1166	22-01-2021	19-02-2021	4th Lift	1.2.4	150 kg/cm2	168.89	167.41	do
	1167						164.44		
7.2	1168						168.89		
	1169	22-01-2021	19-02-2021	4th Lift	1.2.4	150 kg/cm2	164.44	167.41	do
	1170						168.89		
8.1	1171						164.44		
	1172	25-01-2021	22-02-2021	4th Lift	1.2.4	150 kg/cm2	160.00	162.96	do
	1173						164.44		
8.2	1174						164.44		
	1175	25-01-2021	22-02-2021	4th Lift	1.2.4	150 kg/cm2	164.44	165.92	do
	1176						168.89		

JUNIOR ENGINEER.

ASSISTANT ENGINEER

GOVERNMENT OF GOA

SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Construction of protection wall to the side bank of nallah at Rawabhat Shirvoi in ward No. 2 in Quepem Constituency.

SAMPLE SENT BY: AE, SD V, WD XII, WRD, Quepem- Goa.

NAME OF THE AGENCY

TESTING PERIOD

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
1.1	872						168.89		No. WRD/ WD XII/ SD V/ F.15/162/2020-21. DATED: 31-12-2020
	873	16-12-2020	13-01-2021	Foundation	1.2.4	150 kg/cm2	168.89	170.37	
	874						173.33		
1.2	875						173.33		
	876	16-12-2020	13-01-2021	Foundation	1.2.4	150 kg/cm2	168.89	171.85	do
	877						173.33		
2.1	878						173.33		
	879	17-12-2020	14-01-2021	Foundation	1.2.4	150 kg/cm2	173.33	173.33	do
	880						173.33		
2.2	881						173.33		
	882	17-12-2020	14-01-2021	Foundation	1.2.4	150 kg/cm2	173.33	171.85	do
	883						168.89		
3.1	884						173.33		
	885	18-12-2020	15-01-2021	1st Lift	1.2.4	150 kg/cm2	173.33	174.81	do
	886						177.77		
3.2	887						173.33		
	888	18-12-2020	15-01-2021	1st Lift	1.2.4	150 kg/cm2	173.33	173.33	do
	889						173.33		
4.1	890						173.33		
	891	19-12-2020	16-01-2021	1st Lift	1.2.4	150 kg/cm2	168.89	171.85	do
	892						173.33		
4.2	893						173.33		
	894	19-12-2020	16-01-2021	1st Lift	1.2.4	150 kg/cm2	173.33	174.81	do
	895						177.77		

JUNIOR ENGINEER.

ASSISTANT ENGINEER

GOVERNMENT OF GOA

SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Construction of protection wall to the side bank of nallah at Rawabhat Shirvoi in ward No. 2 in Quepem Constituency.

SAMPLE SENT BY: AE, SD V, WD XII, WRD, Quepem- Goa.

NAME OF THE AGENCY

TESTING PERIOD

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
5.1	896						160.00		No. WRD/ WD XII/ SD V/ F.15/162/2020-21. DATED: 31-12-2020
	897	21-12-2020	18-01-2021	1st Lift	1.2.4	150 kg/cm2	160.00	161.48	
	898						164.44		
5.2	899						168.89		
	900	21-12-2020	18-01-2021	1st Lift	1.2.4	150 kg/cm2	164.44	164.44	do
	901						160.00		
6.1	902						164.44		
	903	22-12-2020	19-01-2021	1st Lift	1.2.4	150 kg/cm2	164.44	165.92	do
	904						168.89		
6.2	905						168.89		
	906	22-12-2020	19-01-2021	1st Lift	1.2.4	150 kg/cm2	168.89	167.41	do
	907						164.44		
7.1	908						168.89		
	909	23-12-2020	20-01-2021	1st Lift	1.2.4	150 kg/cm2	164.44	165.92	do
	910						164.44		
7.2	911						173.33		
	912	23-12-2020	20-01-2021	1st Lift	1.2.4	150 kg/cm2	168.89	168.89	do
	913						164.44		
8.1	914						168.89		
	915	24-12-2020	21-01-2021	2nd Lift	1.2.4	150 kg/cm2	173.33	170.37	do
	916						168.89		
8.2	917						173.33		
	918	24-12-2020	21-01-2021	2nd Lift	1.2.4	150 kg/cm2	168.89	171.85	do
	919						173.33		

JUNIOR ENGINEER.

ASSISTANT ENGINEER

GOVERNMENT OF GOA

SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Construction of protection wall to the side bank of nallah at Rawabhat Shirvoi in ward No. 2 in Quepem Constituency.

SAMPLE SENT BY: AE, SD V, WD XII, WRD, Quepem- Goa.

NAME OF THE AGENCY

TESTING PERIOD

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
9.1	920						177.78		No. WRD/ WD XII/ SD V/ F.15/162/2020-21. DATED: 31-12-2020
	921	26-12-2020	23-01-2021	2nd Lift	1.2.4	150 kg/cm2	173.33	176.30	
	922						177.78		
9.2	923						177.78		
	924	26-12-2020	23-01-2021	2nd Lift	1.2.4	150 kg/cm2	173.33	174.81	do
	925						173.33		
10.1	926						173.33		
	927	28-12-2020	25-01-2021	2nd Lift	1.2.4	150 kg/cm2	173.33	174.81	do
	928						177.78		
10.2	929						173.33		
	930	28-12-2020	25-01-2021	2nd Lift	1.2.4	150 kg/cm2	168.89	171.85	do
	931						173.33		
11.1	932						173.33		
	933	29-12-2020	26-01-2021	2nd Lift	1.2.4	150 kg/cm2	173.33	171.85	do
	934						168.89		
11.2	935						168.89		
	936	29-12-2020	26-01-2021	2nd Lift	1.2.4	150 kg/cm2	173.33	170.37	do
	937						168.89		
12.1	938						173.33		
	939	30-12-2020	27-01-2021	2nd Lift	1.2.4	150 kg/cm2	168.89	170.37	do
	940						168.89		
12.2	941						173.33		
	942	30-12-2020	27-01-2021	2nd Lift	1.2.4	150 kg/cm2	173.33	171.85	do
	943						168.89		

JUNIOR ENGINEER.

ASSISTANT ENGINEER