

GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Construction of protection wall to nallah near Sub- Yard of Agriculture marketing board in V.P. Curti of Ponda Taluka.

SAMPLE SENT BY: AE, SD IV, WD XI, WRD, Ponda- Goa.

NAME OF THE AGENCY

TESTING PERIOD

07 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
1	8453						115.56		No. WRD/WD XI/ SD IV/
	8454	5/7/2021	12/7/2021	Foundation Ch. 0.00 m to 7.00 m	1.2.4	100 kg/cm2	120.00	118.52	F.cf/180/2021-22.
	8455						120.00		DATED: 12-07-2021
2	8456						115.56		
	8457	6/7/2021	13-07-2021	Foundation Ch. 7.00 m to 15.00 m	1.2.4	100 kg/cm2	120.00	115.56	do
	8458						111.11		

JUNIOR ENGINEER.

ASSISTANT ENGINEER